



Vendor: BICSI

Exam Code: RCDD

Exam Name: Registered Communications Distribution
Design Exam

Version: DEMO

QUESTION 1

What is the standard floor space allocation used in an office environment for one individual work area?

- A. 100 square feet.
- B. 50 square feet.
- C. 150 square feet.
- D. 75 square feet.

Answer: A

QUESTION 2

NRZ is the acronym for which of the following?

- A. Non-return to zero.
- B. Nominal return zone.
- C. Network registration zone.
- D. Normal return zone.

Answer: A

QUESTION 3

The inadvertent transposition of two conductors of separate pairs is called what?

- A. Twisted pair
- B. Transposed pairs
- C. Reversed pair
- D. Split pair

Answer: D

QUESTION 4

FOTP is an acronym for which of the following?

- A. Fiber Optic Test Procedure.
- B. Fiber Outside Termination Point.
- C. Frequent Optical Transmission Problems.
- D. Fiber Optic Transition Point.

Answer: A

QUESTION 5

Which of the following is an address used to uniquely identify each device on a LAN with an address coded in the network interface card?

- A. MAC
- B. TCP
- C. IP
- D. Physical Layer

Answer: A

QUESTION 6

In what year was BICSI formally incorporated?

- A. 1977
- B. 1984
- C. 1967
- D. 1940

Answer: A

QUESTION 7

In the ceiling zones method of ceiling distribution, divide the usable floor area into zones of how many square feet?

- A. 2000 to 2500 square feet.
- B. 2500 to 3000 square feet.
- C. 365 to 900 square feet.
- D. 1000 to 2000 square feet.

Answer: C

QUESTION 8

In a computer or control room where the plenum is used for heating, ventilating, and air-conditioning, the finished floor height should be a minimum of how many inches?

- A. 8 inches.
- B. 12 inches.
- C. 2 inches.
- D. 6 inches.

Answer: B

QUESTION 9

Which of the following would be the medium duty concentrated load capacity of an access floor in an equipment room?

- A. 100 lbs/square ft.
- B. 50 lbs/square ft.
- C. 1000 lbs/square ft.
- D. 2000 lbs/square ft.

Answer: D

QUESTION 10

What is the typical slab thickness requirement for a two level underfloor duct system where

feeder and distribution ducts intersect?

- A. 4 inch.
- B. 5 inch.
- C. 6 inch.
- D. 7 inch.

Answer: D

QUESTION 11

When designing an underfloor duct system, which of the following would be the cross-sectional area of the duct serving each 100 square feet of floor space with 3 cables to each of the work areas.

- A. 3 square inches.
- B. 4 square inches.
- C. 1 square inches.
- D. 5 square inches.

Answer: C

QUESTION 12

What is the maximum pulling force guideline for a 2 or 4 strand fiber cable?

- A. 100 lbs
- B. 75 lbs
- C. 50 lbs
- D. 25 lbs

Answer: C

QUESTION 13

A horizontal cabling link is distinguished from a horizontal cabling channel because it does not include which of the following.

- A. Equipment cords in the TR.
- B. Does not include a CP.
- C. Does not include a TP.
- D. Cords in the WA that extend beyond the TO/connector.

Answer: AD

Thank You for Trying Our Product

Braindump2go Certification Exam Features:

- ★ More than **99,900** Satisfied Customers Worldwide.
- ★ Average **99.9%** Success Rate.
- ★ **Free Update** to match latest and real exam scenarios.
- ★ **Instant Download** Access! No Setup required.
- ★ Questions & Answers are downloadable in **PDF** format and **VCE** test engine format.
- ★ Multi-Platform capabilities - **Windows, Laptop, Mac, Android, iPhone, iPod, iPad**.
- ★ **100%** Guaranteed Success or **100%** Money Back Guarantee.
- ★ **Fast**, helpful support **24x7**.



View list of all certification exams: <http://www.braindump2go.com/all-products.html>



Microsoft



ORACLE



JUNIPER
NETWORKS



EMC²
where information lives[®]

10% Discount Coupon Code: BDN2014